



IECC Contractor Compliance Form

Property Information	
Project Property Address	
Owner/Contractor	
Address	
Phone	
Email	

- New Construction
- Renovation

I hereby certify that the above project will meet or exceed the minimum requirements of 2009 IECC by utilizing the following measures:

2009 IECC Zone 3A Requirements	Project Specification
Windows $U \leq 0.50$	
Windows SHGC ≤ 0.30	
Skylight $U \leq 0.65$	
Skylight SHGC ≤ 0.30	
Doors (1 door $\leq 24\text{sqft}$ exempt) ≤ 0.65	
Ceiling Insulation R-30	
Wall Insulation R-13	
Floor Insulation R-19 or Crawl R-5 continuous / R-13 cavity	
HVAC Efficiency Rating	
HVAC sized in accordance with ACCA Manual J	
Heat pumps have adaptive recovery thermostats	
Duct Insulation R-8 in unconditioned space & R-6 in floor trusses	
Return from enclosed rooms must meet ACCA Manual D	
Ducts sealed and tested per Table 402.42 (list party)	
Building Envelope: air seal test or verification required (list party)	
Recessed Cans – IC air tight (ICAT)	
Mech. system pipes carrying fluids above 105°F insulated to R-3	
Circ. hot water system pipes carrying fluids above 105°F insulated to R-2	
50 % of lamps must be high-efficient	

Note: If any project specification does not meet the minimum IECC requirements, then a RESCheck or other approved simulation model must be performed and submitted with the permit application.

Signature

Date